# K50 Pro Indicator



# Datasheet

50 mm Programmable Multicolor RGB Indicator with Audible Models and an Optional Flashing Input Control

Bright, uniform indicator light

Variety of connector options

30 mm threaded polycarbonate base Translucent polycarbonate dome

Compact models available for lower profile applications

Bimodal inputs (PNP/NPN), depending on source wiring

Models constructed from FDA-grade materials available

Models with integrated audible alarm available

•

• •

•



### Standard model



Compact model

# Pro Editor




Use Banner's Pro Editor software and Pro Converter Cable to create custom configurations by selecting different colors, flash patterns, and animations.

Seven default colors in one device (Green, Red, Yellow, Blue, White, Cyan, Magenta) Programmable using Banner's Pro Editor software and Pro Converter Cable

Rugged IEC IP66, IEC IP67, IP69K per DIN 40050-9 and UL Type 4X, 13 design

For more information visit www.bannerengineering.com/proeditor.

# Models




Audible models not available in FDA-grade material or compact models

\*\* Compact models and Integral quick disconnect models not available in FDA-grade material \*\*\* Models with a quick disconnect require a mating cordset



## Wiring Diagrams



#### Table 1: Default Color Definition

	Red	Yellow	Green	Cyan	Blue	Magenta	White
Input 1	х	х				х	х
Input 2		Х	Х	Х			Х
Input 3				Х	Х	Х	Х

An "X" denotes an active input, for example when Input 1 and Input 3 are active, the indicator will show Magenta.

# Specifications

### Supply Voltage and Current

- 10 V dc to 30 V dc
  - 220 mA at 10 V dc
  - 190 mA at 12 V dc
  - 115 mA at 24 V dc ٠

# 100 mA at 30 V dc

### Supply Protection Circuitry

Protected against reverse polarity and transient voltages

#### Leakage Current Immunity

#### 400 µA

#### Input Response Time

250 milliseconds maximum

#### Flash

Default 1.5 Hz flash rate using flash input wire (not available on audible models

### Audible Alarm

- All models have a steady tone
- A1 Model: 75 dB at 1 meter (typical), 3 kHz  $\pm$  500 Hz
- AL1 Model: 95 dB at 1 meter (typical), 2.7 kHz ± 500 Hz
- ALS Model: 94 dB at 1 meter (typical), 2.9 kHz ± 250 Hz

### Connections

Integral 5-pin M12/Euro-style quick disconnect, 150 mm (6 in) PVC cable with a M12/Euro-style quick disconnect, or 2 m (6.5 ft) integral PVC cable, depending on model

Models with a quick disconnect require a mating cordset

#### Mounting

M30 by 1.5 threaded base, maximum torque 4.5 N·m (40 inch-lbf) Mounting nut included

#### **Pro Editor Configuration**

Connection to Pro Editor software enables control of:

- Animation: On, Flash, Two Color Flash, 50/50, 50/50 Rotate,
- Chase, Intensity Sweep, Demo
- Color: Green, Red, Yellow, Blue, White, Cyan, Magenta, Amber, Rose, Lime Green, Orange, Sky Blue, Violet, Spring Green
- Intensity: Low, Medium, High
- Speed: Slow, Standard, Fast
- Pro Converter Cable required to interface between PC and indicator, see accessories

#### **Default Indicator Characteristics**

Color	Dominant Wavelength (nm) or Color Temperature	Color Coordinates <sup>1</sup>		Lumen Output
	(CCT)	x	У	- (Typical at 25 °C) <sup>2</sup>
Green	530 nm	0.170	0.711	21.4
Red	625 nm	0.688	0.310	6.3
Yellow	-	0.457	0.485	17.2
Blue	470 nm	0.133	0.072	4.7
White	5950 K	0.323	0.336	21.3
Cyan	-	0.154	0.321	25.1
Magenta	-	0.365	0.176	8.5

Refer to CIE 1931 chromaticity diagram or color chart, to show equivalent color with indicated color coordinates Values shown apply to dome models only. Compact models are 20% lower.

1 2

#### Construction

Standard and Compact Model Base, Dome, and Nut: Polycarbonate FDA Model Base, Dome, and Nut: FDA-grade polycarbonate

#### Vibration and Mechanical Shock

Meets IEC 60068-2-6 requirements (Vibration: 10 Hz to 55 Hz, 1.0 mm amplitude, 5 minutes sweep, 30 minutes dwell)

Meets IEC 60068-2-27 requirements (Shock: 30G 11 ms duration, half sine wave)

#### **Operating Conditions**

-40 °C to +50 °C (-40 °F to +122 °F) 90% at +50 °C maximum relative humidity (non-condensing) Storage Temperature: -40 °C to +70 °C (-40 °F to +158 °F)

#### **Environmental Rating**

Standard and Compact Models:

- Non-Audible Models: IEC IP66, IEC IP67, IP69K per DIN 40050-9
- A1 and AL1 Models: IEC IP50

ALS Models: IEC IP66, IEC IP67, IP69K per DIN 40050-9

- Meets UL Type 4X, 13 when used in a suitable enclosure Cabled models also meet IP69K per DIN 40050-9 if the cable and cable
- entrance are protected from high-pressure spray
- FDA Models: IEC IP66, IEC IP67, IP69K per DIN 40050-9

### Certifications





#### **Required Overcurrent Protection**



WARNING: Electrical connections must be made by qualified personnel in accordance with local and national electrical codes and regulations.

Overcurrent protection is required to be provided by end product application per the supplied table. Overcurrent protection may be provided with external fusing or via Current Limiting, Class 2 Power Supply. Supply wiring leads < 24 AWG shall not be spliced.


For additional product support, go to www.bannerengineering.com.

Supply Wiring (AWG)	Required Overcurrent Protection (Amps)		
20	5.0		
22	3.0		
24	2.0		
26	1.0		
28	0.8		
30	0.5		


## Dimensions

All measurements are listed in millimeters [inches], unless noted otherwise.


## A1 and AL1 Audible Models




### Non-Audible Models




**ALS Audible Models** 



### **Cabled Models**




## **Compact Models**



# Accessories

# Pro Editor Hardware



# Cordsets

5-Pin Threaded M12/Euro-Style Cordsets—Single Ended					
Model	Length	Style	Dimensions	Pinout (Female)	
MQDC1-501.5	0.50 m (1.5 ft)		44 Typ		
MQDC1-506	1.83 m (6 ft)				
MQDC1-515	4.57 m (15 ft)	Straight			
MQDC1-530	9.14 m (30 ft)		M12 x 1 → ø 14.5 →		
MQDC1-506RA	1.83 m (6 ft)				
MQDC1-515RA	4.57 m (15 ft)	Right-Angle	32 Тур	4 -> \_5	
MQDC1-530RA	9.14 m (30 ft)		(1.26") 30 Typ. 11.18" 0 14.5 [0.57"]	1 = Brown 2 = White 3 = Blue 4 = Black 5 = Gray	

5-Pin Threaded M12/Euro-Style Cordsets—Washdown Stainless Steel						
Model	Length	Style	Dimensions	Pinout (Female)		
MQDC-WDSS-0506	1.83 m (6 ft)			~2		
MQDC-WDSS-0515	4.57 m (15 ft)			1-		
MQDC-WDSS-0530	9.14 m (30 ft)	Straight	Ø15.5 mm 04.8 mm 04.8 mm	4 - 3 $4 - 3$ $4 - 3$ $4 - 3$ $4 - 3$ $4 - 3$ $4 - 3$ $4 - 3$ $4 - 3$ $4 - 3$ $5 -$		

# Brackets



- Right-angle bracket with curved slot for versatile orientation
- Clearance for M6 (¼ in) hardware
- Mounting hole for 30 mm sensor
- 12-ga. stainless steel

Hole center spacing: A to B=40 Hole size: A=Ø 6.3, B= 27.1 x 6.3, C=Ø 30.5

#### SMB30RAVK

- V-clamp, right-angle bracket and fasteners for mounting sensors to pipe or extrusion
  - Clamp accommodates 28 mm dia. tubing or 1 in. square extrusions
- 30 mm hole for mounting sensors

Hole size: A = Ø 30.5

#### SMBAMS30RA


- Right-angle SMBAMS series bracket
  30 mm hole for mounting
- sensors
- Articulation slots for 90°+ rotation
- 12-ga. (2.6 mm) cold-rolled steel

Hole center spacing: A=26.0, A to B=13.0 Hole size: A=26.8 x 7.0, B=ø 6.5, C=ø 31.0

#### SMB30SC

- Swivel bracket with 30 mm
- mounting hole for sensorBlack reinforced thermoplastic
- polyesterStainless steel mounting and
- swivel locking hardware included

Hole center spacing: A=ø 50.8 Hole size: A=ø 7.0, B=ø 30.0



### SMB30FVK

## V-clamp, flat bracket and fasteners for mounting to pipe or extensions Clamp accommodates 28 mm

dia. tubing or 1 in. square extrusions30 mm hole for mounting



Hole size: A= Ø 31

# SMBAMS30P Flat SMBAMS series bracket

sensors

- 30 mm hole for mounting sensors
- Articulation slots for 90°+
- 12-ga. 300 series stainless steel



83.2

36.3

68.9

Hole center spacing: A=26.0, A to B=13.0 Hole size: A=26.8 x 7.0, B=Ø 6.5, C=Ø 31.0

### SMB30MM

- 12-ga. stainless steel bracket with curved mounting slots for versatile orientation
- Clearance for M6 (¼ in) hardware
- Mounting hole for 30 mm sensor

Hole center spacing: A = 51, A to B = 25.4Hole size:  $A = 42.6 \times 7$ ,  $B = \emptyset \ 6.4$ ,  $C = \emptyset \ 30.1$ 

#### SMB30FA

- Swivel bracket with tilt and pan movement for precise adjustment
- Mounting hole for 30 mm sensor
- 12-ga. 304 stainless steel
- Easy sensor mounting to
- extrude rail T-slot
- Metric and inch size bolt available

Bolt thread: SMB30FA, A= 3/8 - 16 x 2 in; SMB30FAM10, A= M10 - 1.5 x 50 Hole size: B= ø 30.1

#### LMBE12RA35


- Direct mounting of stand-off pipe, with common bracket type
- Zinc-plated steel
- 1/2-14 NPSM nut
- Mounting distance from the wall to the NPSM NUT center of the 1/2-14 NPSM nut is 35 mm

Hole center spacing: 20.0

### LMBE12RA45

- Direct mounting of stand-off pipe, with common bracket type
- Zinc-plated steel
- 1/2-14 NPSM nut
- Mounting distance from the wall to the center of the 1/2-14 NPSM nut is 45 mm

Hole center spacing: 35.0



All measurements are listed in millimeters [inches], unless noted otherwise.

55

2X Ø9

1/2 - 14

35

38.25

0

Q

57

# Banner Engineering Corp. Limited Warranty

Banner Engineering Corp. warrants its products to be free from defects in material and workmanship for one year following the date of shipment. Banner Engineering Corp. will repair or replace, free of charge, any product of its manufacture which, at the time it is returned to the factory, is found to have been defective during the warranty period. This warranty does not cover damage or liability for misuse, abuse, or the improper application or installation of the Banner product.

THIS LIMITED WARRANTY IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES WHETHER EXPRESS OR IMPLIED (INCLUDING, WITHOUT LIMITATION, ANY WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE), AND WHETHER ARISING UNDER COURSE OF PERFORMANCE, COURSE OF DEALING OR TRADE USAGE.

This Warranty is exclusive and limited to repair or, at the discretion of Banner Engineering Corp., replacement. IN NO EVENT SHALL BANNER ENGINEERING CORP. BE LIABLE TO BUYER OR ANY OTHER PERSON OR ENTITY FOR ANY EXTRA COSTS, EXPENSES, LOSSES, LOSS OF PROFITS, OR ANY INCIDENTAL, CONSEQUENTIAL OR SPECIAL DAMAGES RESULTING FROM ANY PRODUCT DEFECT OR FROM THE USE OR INABILITY TO USE THE PRODUCT, WHETHER ARISING IN CONTRACT OR WARRANTY, STATUTE, TORT, STRICT LIABILITY, NEGLIGENCE, OR OTHERWISE.

Banner Engineering Corp. reserves the right to change, modify or improve the design of the product without assuming any obligations or liabilities relating to any product previously manufactured by Banner Engineering Corp. Any misuse, abuse, or improper application or installation of this product or use of the product for personal protection applications when the product is identified as not intended for such purposes will void the product warranty. Any modifications to this product without prior express approval by Banner Engineering Corp will be the product warranty. void the product warranties. All specifications published in this document are subject to change; Banner reserves the right to modify product specifications or update documentation at any time. Specifications and product information in English supersede that which is provided in any other language. For the most recent version of any documentation, refer to: www.bannerengineering.com

For patent information, see www.bannerengineering.com/patents.

# FCC Part 15 and CAN ICES-3 (B)/NMB-3(B)

This device complies with part 15 of the FCC Rules and CAN ICES-3 (B)/NMB-3(B). Operation is subject to the following two conditions:

- 1. This device may not cause harmful interference, and
- This device must accept any interference received, including interference that may cause undesired operation 2.

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules and CAN ICES-3 (B)/NMB-3(B). These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver. .
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the manufacturer

